


dar

FOR CONSTRUCTION


PRESIDENTIAL PARK **AMPHITHEATRE BUILDING-**HANDHOLE INSTALATION DETAILS


Project No. Phase code Project part Department Acronym Sheet No.


APPROVED




SECTION 1















LEGEND:-

S	YMBOLS	DESCRIPTION
FII	RE ALARM SYST	EM
	A B	FIRE ALARM DETECTOR A= TYPE: S: IONIZATION SMOKE DETECTOR O: PHOTOELECTRIC SMOKE DETECTOR H: FIXED TEMEPERATURE THERMAL DETECTOR R: RATE OF RISE/FIXED TEMEPERATURE THERMAL DETECTOR F: FLAME DETECTOR L= LASER-TYPE SMOKE DETECTOR M: MULTI-SENSOR DETECTOR D: DUCT SMOKE DETECTOR
		B=ACCESSORY (IF ADDED): S: WITH SOUNDER BASE H: FOR HARSH ENVIRONMENT CO: CARBON MONOXIDE DETECTOR
	<\(\hat{0}\)>	ABOVE FALSE CEILING PHOTOELECTRIC SMOKE DETECTOR
	<u></u>	UNDER RAISED FLOOR PHOTOELECTRIC SMOKE DETECTOR
	тх В	OPTICAL BEAM SMOKE DETECTOR - TRANSMITTER
	RX B	OPTICAL BEAM SMOKE DETECTOR - RECEIVER
	F	MANUAL STATION
	0	FIRE ALARM BELL
		FIRE ALARM BELL WITH STROBE LIGHT
		CEILING MOUNTED STROBE LIGHT
	<u> </u>	WALL MOUNTED STROBE LIGHT
		FIRE ALARM HORN (T=H1,H2 OR H3 REFER. SPECIFICATIONS)
		FIRE ALARM HORN WITH STROBE LIGHT (T=H1, H2 OR H3 REFER. SPECIFICATIONS)
	○ F	FIRE EVACUATION SPEAKER
	⊗F	FIRE EVACUATION SPEAKER WITH STROBE LIGHT
	HOF	WALL MOUNTED FIRE EVACUATION SPEAKER WALL MOUNTED FIRE EVACUATION SPEAKER
	H⊗F	WITH STROBE LIGHT
	⊢ ⊘ F	WALL MOUNTED HIGH DIRECTIVITY FIRE EVACUATION SPEAKER
	F(X)	REMOTE INDICATOR
	DH I	MAGNETIC DOOR HOLDER
		FIRE ALARM TERMINAL CABINET
	[n	(n=FLOOR AND SERIAL NUMBER)
	MFACP	FIRE ALARM REPEATER PANEL MAIN FIRE ALARM CONTROL PANEL
	FACP	FIRE ALARM CONTROL PANEL
	FAAP	FIRE ALARM ANNUNCIATOR PANEL
	RIP	REFUGE INTERCOM PANEL
		WATER FLOW SWITCH (PART OF MECHANICAL WORK)
	X	TAMPER SWITCH (PART OF MECHANICAL WORK)
	СМ	CONTROL MODULE
	ММ	MONITOR MODULE
	F	FIRE FIGHTER TELEPHONE OUTLET
		FIRE FIGHTER TELEPHONE STATION
	[] _{RI}	REFUGE INTERCOM STATION
	FCC	FIRE COMMAND CENTER
	— н —	LINEAR HEAT DETECTOR
	LHDP	LINEAR HEAT DETECTOR PANEL
	(DR)	ELECTROMAGNETIC FIRE-BREAK DOOR RELEASE DEVICE
	CZM	CONVENTIONAL ZONE MODULE
	PSU	REMOTE POWER SUPPLY UNIT
	CTV SYSTEM	CCTV CENTRAL CONCOLE
	CCTV	CCTV CENTRAL CONSOLE MATRIX SWITCHER
	VS	VIDEO SWITCHER
		CEILING CAMERA , FIXED TYPE
		CEILING CAMERA , CONTROLLABLE TYPE
		CEILING DOME CAMERA , FIXED TYPE
		CEILING DOME CAMERA , CONTROLLABLE TYPE
		WALL MOUNTED CAMERA , FIXED TYPE
		WALL MOUNTED CAMERA , CONTROLLABLE TYPE
		WALL MOUNTED DOME CAMERA , FIXED TYPE
	H	WALL MOUNTED DOME CAMERA , CONTROLLABLE TYPE

mD/nT/xV V	WALL MOUNTED INFORMATION OUTLET m: NUMBER OF DATA (D) PORTS (1,2,3,ETC.) n: NUMBER OF TELEPHONE (T) PORTS x: NUMBER OF VIDEO (V) PORTS Y: OUTLET SERVICES (AS SHOWN BELOW)
mT/nD/xV	FLOOR MOUNTED INFORMATION OUTLET m: NUMBER OF DATA (D) PORTS (1,2,3,ETC.) n: NUMBER OF TELEPHONE (T) PORTS x: NUMBER OF VIDEO (V) PORTS Y: OUTLET SERVICES (AS SHOWN BELOW)
mT/nD/xV	FURNITURE MOUNTED INFORMATION OUTLET m: NUMBER OF DATA (D) PORTS (1,2,3,ETC.) n: NUMBER OF TELEPHONE (T) PORTS x: NUMBER OF VIDEO (V) PORTS Y: OUTLET SERVICES (AS SHOWN BELOW)
mD/xV	CEILING INFORMATION OUTLET m: NUMBER OF DATA (D) PORTS (1,2,3,ETC.) x: NUMBER OF VIDEO (V) PORTS Y: OUTLET SERVICES
	 W:WALL MOUNTED TELEPHONE WIFI: WIRELESS ACCESS POINT DS: DIGITAL SIGNAGE CCTV: CAMERAS ACS: ACCESS CONTROL BMS: BMS PANELS FA: FIRE ALARM CONTROL PANELS VM: VENDING MACHINE POS: POINT OF SALE ATM: AUTOMATED TELLER MACHINE POF: PAY ON FOOT MACHINE PGS: PARKING GUIDANCE SYSTEM IC: INTERCOM SS: SECURITY SCREENING PA: PUBLIC ADDRESS EV: ELECTRICAL VEHICLE BC: BARRIER CONTROLLER LPR: LICENSE PLATE RECOGNITION TD: TICKET DISPENSER
H(AP)	WIRELESS ACCESS POINT LOCATION, WALL MOUNTED
(AP)	WIRELESS ACCESS POINT LOCATION, CEILING MOUNT
CP S	CONSOLIDATION POINT (T=F:FIBER OR C:COPPER , S=SIZE)
ПС	TENANT TELECOM CABINET
TCR	TELECOMMUNICATIONS RACK
SC	SERVER CABINET
ТСС	TELECOMMUNICATIONS CABINET
ODF	OPTICAL DISTRIBUTION FRAME
IEC	INDOOR EQUIPMENT CABINET
PUBLIC ADDRES	SS / SOUND SYSTEM
SC	SOUND SYSTEM TERMINAL CABINET
<u> </u>	PLUG-IN MICROPHONE
O _{Zn}	CEILING MOUNTED SPEAKER (Zn=REFERS TO ZONE NUMBER)
O _P	PENDANT MOUNTED SPEAKER
HOZn	WALL MOUNTED/ COLUMN SPEAKER (Zn=REFERS TO ZONE NUMBER)
	PREAMPLIFIER / MIXER
	AMPLIFIER
00	TAPE RECORDER
Δ	MICROPHONE WITH PLUG
VC	VOLUME CONTROL
VC SC	VOLUME CONTROL WITH CHANNEL SELECTION
PS	PAGING STATION

SYMBOLS	DESCRIPTION		
INFRASTRUCTUR	RE NETWORKS		
	HAND HOLE		
	EMERGENCY TELEPHONE, WEATHER PROOF		
FP	FEEDER PILLAR		
TC	TELECOMMUNICATION DISTRIBUTION CABINET		
DS	DIGITAL SIGNAGE		
ACCESS CONTRO	L SYSTEM		
CR	CARD READER		
EL	ELECTRIC LOCK		
ML	MAGNETIC LOCK		
DIU	DOOR INTERFACE UNIT		
ACP	ACCESS CONTROL PANEL		
Р	PANIC BUTTON		
РВ	PUSH BUTTON		
(DC)	DOOR CONTACT		
EAB	EMERGENCY ALARM BUTTON		
CS	COUNTER SENSOR		
TE	TAG EXCITER		
	DOOR TYPE		
XX XX-##	ACS DOOR DETAIL REFERENCE		
	SEQUENCE NUMBER		
	BUILDING FLOOR/LEVEL NUMBER		
	HIGHER LEVEL OF SECURITY		
†	ACCESS CONTROLLED DOOR SYMBOL		
<u> </u>	LOWER LEVEL OF SECURITY		



BUILDINGS NOTES

GENERAL NOTES

- 1. THE LAYOUT DRAWINGS DO NOT SHOW ALL THE SYSTEMS, ITEMS, OR ACCESSORIES COVERED UNDER THE SCOPE OF TELECOM WORKS TO BE EXECUTED. THE LAYOUT DRAWINGS SHALL BE READ IN CONJUNCTION WITH ALL RELEVANT OR SPECIALIST DRAWINGS AND SPECIFICATIONS. IT IS THE CONTRACTOR'S RESPONSIBILITY TO PROVIDE ALL ITEMS NECESSARY TO ACHIEVE A FULLY FUNCTIONAL SYSTEM TO MEET THE SPECIFICATIONS / DESIGN INTENT AND RESPECTIVE
- 2.DO NOT SCALE FROM THE LAYOUT DRAWINGS, WORK ACCORDING TO ARCHITECTURAL OR TELECOM DETAILS UNLESS OTHERWISE INDICATED.
- 3. THE SIZE OF CONDUITS IS IN GENERAL NOT SHOWN ON THE DRAWINGS. THE SIZE OF ALL CONDUITS SHALL BE SELECTED IN ACCORDANCE WITH THE "REGULATIONS" AND AS A FUNCTION OF THE NUMBER & SIZE OF THE INDICATED CONDUCTORS. ALL CONDUITS SHALL BE AS SPECIFIED WITH A MINIMUM SIZE OF Ø20mm UNLESS OTHERWISE INDICATED.
- 4. ALL EXPOSED CONDUITS INSTALLED IN PLANT AREAS ARE TO BE STEEL TYPE AS PER PROJECT
- SPECIFICATIONS, UNLESS OTHERWISE INDICATED. 5. CONTRACTOR IS TO ENSURE THAT PROPER CLEARANCE IS PROVIDED BETWEEN POWER AND TELECOM COPPER CABLES RUNS (PARALLEL & PERPENDICULAR) IN ORDER TO AVOID ELECTROMAGNETIC INTERFERENCE / INFLUENCE BETWEEN POWER AND TELECOM CABLES AS PER APPLICABLE LOCAL /
- INTERNATIONAL REGULATIONS AND STANDARDS. 6. CONTRACTOR IS TO ENSURE THE ACCESSIBILITY OF ALL TELECOM INSTALLATIONS AND EQUIPMENT FOR FUTURE MAINTENANCE / REPLACEMENT. CONTRACTOR IS TO PROVIDE ALL REQUIRED
- STRUCTURES, SUPPORTS AND ACCESSORIES NECESSARY FOR THE PROPER FIXATION OF ALL EQUIPMENT, RACEWAYS, ETC. IN LOCATIONS THAT ENSURE THEIR SAFETY AND ACCESSIBILITY 7. SMART FIELD DEVICES (I.E. CCTV CAMERAS, PUBLIC ADDRESS AMPLIFIERS, PARKING GUIDANCE DISPLAY, PARKING CONTROLLERS, ACCESS CONTROL PANELS, EMERGENCY STATION, INTERNAL
- TELEPHONE, ETC.) WILL BE CONNECTED TO THE COC/CCC THROUGH THE SSN. 8. SMART PARKING, VIDEO SURVEILLANCE, ACCESS CONTROL AND FIRE ALARM SYSTEMS WILL BE MANAGED FROM COC/CCC CENTRALIZED PLATFORM. CONTRACTOR SHALL GUARANTEE INTEGRATION WITH COC/CCC PLATFORM AND IS RESPONSIBLE TO COORDINATE WITH THE CLIENT/ACUD TO
- PROVIDE ALL REQUIRED INTEGRATION ELEMENTS REQUIRED FOR A FULLY FUNCTIONAL SYSTEM. 9.FOR OTHER SYSTEM THAT AREN'T INCLUDED IN COC PLATFORM (PUBLIC ADDRESS, INTERNAL TELEPHONY, EMERGENCY STATION, PEOPLE COUNTING AND LOCATING SYSTEMS); CONTRACTOR OF CP01A SHALL PROVIDE THE REQUIRED SOFTWARE FOR THE RELATED DEVICES ALLOCATED AT CP01 (CP01A, CP01B AND CP01C) TO BE HOSTED AT THE COC. THESE SYSTEMS SHALL BE FULLY INTEGRATED WITH COC PLATFORM

FIRE ALARM SYSTEM NOTES

- 1. FIRE ALARM DETECTION AND ALARM SYSTEM IS DESIGNED IN ACCORDANCE WITH THE REQUIREMENTS OF NFPA 70, 72, 101, 5000 AND FIRE SAFETY GUIDE LINES OF CIVIL DEFENSE DEPARTMENT.
- 2.FOR CORE & SHELL SPACES, NOT MORE THAN 50 % OF SIGNALING LOOP CAPACITY TO BE CONSIDERED FOR INITIAL INSTALLATION AND OPERATION. FOR FULLY FURNISHED SPACES, THE QUANTITY OF ADDRESSABLE DEVICES (DETECTORS + MODULES) PER LOOP SHALL NOT EXCEED 80% OF THE MAXIMUM CAPACITY SO AS TO MAINTAIN A 20% SPARE CAPACITY.
- 3. PRESIDENTIAL PARK OPERATOR SHALL ENSURE THAT ADDED DEVICES IN CORE & SHELL AREAS ARE OF THE SAME TYPE OF DEVICES USED AND TO BE COMPATIBLE WITH INSTALLED FIRE ALARM PANELS/
- 4.FIRE ALARM SYSTEM CABLES SHALL COMPLY WITH BS 5839-1 CLAUSE 26.2(D) STANDARD, FLAME RETARDANT, LOW SMOKE ZERO HALOGEN.
- 5. FIRE ALARM SYSTEM WIRING SHALL BE CONFIGURED AS "CLASS A" WIRING. THE OUTGOING & RETURN CIRCUIT CONDUCTORS SHALL NOT RUN IN THE SAME CABLE ASSEMBLY, RACEWAY OR ENCLOSURE.
- 6. CONDUCTOR SIZES SHALL BE 2CX1.5MM2 FOR SIGNALING LINE CIRCUITS AND 2CX2.5MM2 FOR NOTIFICATION LINE CIRCUITS, HOWEVER THE CONTRACTOR SHALL VERIFY THE CONNECTED LOADS AND PROVIDE CONDUCTORS IN SECTIONS TO COMPENSATE FOR VOLTAGE DROPS AND ENSURE PROPER COMPONENT OPERATION.
- 7.EQUIPMENT, INSTALLATION, WORKMANSHIP, INSPECTION, AND TESTING SHALL BE IN STRICT ACCORDANCE WITH THE REQUIREMENTS OF NFPA-72 - 2019, "NATIONAL FIRE ALARM AND SIGNALING
- 8. ALL INSTALLATIONS SHALL BE AFTER FULL COORDINATION WITH ALL TRADES, ANY DEVIATION FROM DESIGN DRAWINGS SHALL BE RESOLVED AND APPROVED ACCORDINGLY.
- 9. THE CONTRACTOR SHALL SUBMIT SHOP DRAWINGS, CATALOGUE AND MATERIAL SAMPLES FOR APPROVAL BY CONSULTING ENGINEER PRIOR TO ACTUAL PROCUREMENT AND INSTALLATION. THE CONTRACTOR SHALL PROVIDE DETAILS OF THE VARIOUS COMPONENTS OF THE FIRE ALARM SYSTEM INSTALLATION BASED ON THE APPROVED PLANS AND ACTUAL MANUFACTURER'S DATA.
- 10. CONTRACTOR SHALL PROVIDE NECESSARY INTERFACES MODULE FOR ALL SMOKE CONTROL EQUIPMENT SUCH AS PRESSURIZATION FANS, SMOKE EXTRACTION FANS, SMOKE CONTROL MOTORIZED DAMPERS, ETC. WHERE APPLICABLE.
- 11. DUCT SMOKE DETECTORS SHALL BE PROVIDED ON SUPPLY AIR SYSTEM AND TO BE CONNECTED TO THE NEAREST SIGNALING LOOP.
- 12. CONTRACTOR SHALL PROVIDE NECESSARY INTERFACES MODULE FOR ALL FIRE SUPPRESSION SYSTEMS SUCH AS PRE-ACTION SYSTEM, DELUGE VALVE SYSTEM AND ZONE VALVES WHERE
- APPLICABLE. 13. SPACES PROTECTED BY AUTOMATIC FIRE SUPPRESSION SYSTEM (FM200) (REFER TO MECHANICAL PACKAGE) SHALL BE INTERFACED WITH FIRE ALARM CONTROL PANEL TO PROVIDE FULL SYSTEM INFORMATION INCLUDING (ALARM, GAS RELEASED, SYSTEM TROUBLE) SIGNALS.
- 14. CONTRACTOR SHALL PROVIDE NECESSARY INTERFACES CONTROL MODULE FOR ALL SECURED DOORS IN EGRESS PATH TO OPEN IN CASE OF FIRE.
- 15. CONTRACTOR SHALL PROVIDE NECESSARY INTERFACES TO FIRE DOOR HOLDERS, FIRE/SMOKE CURTAINS, FIRE SHUTTERS, ETC. AS INDICATED ON ARCHITECTURE DRAWING WHERE APPLICABLE.
- 16. THE AUTOMATIC OPERATIONS SHALL BE UNDERTAKEN FROM SYSTEM BASED ON THE FINAL CAUSE & EFFECT MATRIX SUBMITTED BY THE CONTRACTOR FOR APPROVAL.
- 17. FAULT ISOLATOR MODULES SHALL BE PROVIDED AS PER NFPA 72 REQUIREMENTS. 18. DETECTION AND NOTIFICATION DEVICES IN CORE & SHELL AREAS PROVIDE THE MINIMUM REQUIRED
- COVERAGE, FINAL LOCATIONS AND QUANTITIES SHALL BE PROVIDED AS PER FINAL INTERIOR LAYOUTS. TENANT/ PRESIDENTIAL PARK OPERATOR SHALL COORDINATE ALL NECESSARY MODIFICATIONS/ADDITIONS.
- 19. WIRING AT TENANT SPACE SHALL ALLOW FUTURE ISOLATION FOR THE DETECTORS WITHIN THE TENANT SPACE WITHOUT AFFECTING THE OPERATION OF DEVICES ON THE SAME SIGNALING CIRCUIT, FAULT ISOLATOR MODULE SHALL BE PROVIDED AT EACH TENANT SPACE ACCORDINGLY.
- 20. VISIBLE APPLIANCES CD LEVEL SHALL BE SET AS PER NFPA 72 CODE REQUIREMENTS, REFER TO TABLE 18.5.5.4.1.
- 21. CONTRACTOR TO ENSURE THAT ALL FIRE ALARM DEVICES ARE MADE ACCESSIBLE FOR MAINTENANCE. 22. THE NUMBER OF ADDRESSABLE LOOPS SHOWN ON THE RISER DIAGRAM ARE INDICATIVE ONLY. THE FINAL NUMBER OF LOOPS SHALL DEPEND ON THE MANUFACTURER'S STANDARD (NUMBER OF DEVICES PER LOOP) PLUS ONE (1) SPARE LOOP PER FACP.

TELECOMMUNICATION SYSTEMS NOTES

- 1. ALL CONDUITS SHALL BE PVC EMBEDDED CONDUITS UNLESS/OTHERWISE INDICATED. 2. CABLE CONVEYANCE PATHWAYS INDICATED ON DRAWINGS ARE DIAGRAMMATIC. COORDINATE ROUTING AND FINAL LOCATIONS OF PATHWAYS WITH OTHER OVERHEAD SYSTEMS AND SITE
- 3. CONTRACTOR TO PROVIDE A COMPLETE AND FUNCTIONAL CABLE CONVEYANCE SYSTEM CONSISTENT WITH OVERHEAD SUPPORT AND ATTACHMENT COMPONENTS. AT EVERY POINT THROUGHOUT THE ROUTING PATHWAY, FIBER OPTICAL CABLE BENDING RADIUS SHALL FOLLOW MANUFACTURER'S
- RECOMMENDATIONS. 4. CONDUIT PATHWAYS SHALL NOT EXCEED 30 METERS BETWEEN PULL BOX LOCATIONS. CONDUIT
- PATHWAYS SHALL NOT EXCEED 90° BENDS BETWEEN PULL BOXES. 5. GROUND ALL CONDUITS, CABLE TRAYS AND JUNCTION BOXES AS PER THE MANUFACTURER'S
- RECOMMENDATIONS AND AS PER ALL APPLICABLE CODES. 6. ALL CABLE TRANSITIONS FROM THE LADDER TRAY TO THE CABINETS SHALL BE ROUTED VIA PROPER TRANSITION HARDWARE SUCH AS, BUT NOT LIMITED TO, WATERFALLS OR RUNWAY TO RACK
- TRANSITIONS TO MAINTAIN PROPER CABLE BEND RADIUS. 7. INSTALL FIRE STOP ASSEMBLIES TO ALL THROUGH-SLAB AND THROUGH-WALL PENETRATIONS FOR
- THE INSTALLATION OF CABLES AS REQUIRED TO MAINTAIN FIRE RATING OF SLAB OR WALL. 8. ALL DATA OUTLETS IN SUPPORT SPACES INCLUDING, BUT NOT LIMITED TO. MECHANICAL, BMS, ELECTRICAL, PLUMBING, SECURITY AND FIRE ALARM - CONTRACTOR SHALL COORDINATE DATA OUTLET FINAL LOCATION IN THE ROOM ON SHOP DRAWINGS WITH ALL OTHER SYSTEM CONTRACTORS
- AS REQUIRED TO SUPPORT THE SYSTEMS IN THE ROOM. 9. FURNITURE MOUNTED DATA/TELEPHONE OUTLETS AND CORRESPONDING POWER SOCKET(S) SHALL BE HOUSED IN THE SAME TABLE BOX.
- 10. OUTLETS FACEPLATES SELECTION SHALL FOLLOW THE SAME SELECTION AS LIGHTING AND POWER
- 11. THE DEVICES SHALL BE CONNECTED TO THE NEAREST ONT. IF THE MAXIMUM DISTANCE BETWEEN ONT AND THE END DEVICES EXCEEDS 90M, THEN FIBER AND NECESSARY MEDIA CONVERTERS SHALL
- BE USED AND LOCAL UPS POWER SUPPLY SHALL BE ARRANGED ACCORDINGLY. 12. CABINET ELEVATIONS ARE DIAGRAMMATIC IN NATURE TO REFLECT SYSTEM ASSIGNMENTS AND BASIS OF DESIGN EQUIPMENT ALLOCATIONS. THE CONTRACTOR SHALL PROVIDE THE ALL EQUIPMENT
- BASED ON APPROVED SYSTEM SHOP DRAWINGS. 13. ALL INFORMATION TECHNOLOGY OUTLETS RATING WILL FOLLOW SAME ENVIRONMENTAL RATING OF
- ELECTRICAL SOCKETS WITHIN THE SPACE. 14. FOR FLOOR BOX MOUNTED OUTLETS, COORDINATE MOUNTING INTO SAME ELECTRICAL SOCKET
- 15. LOCATION & QUANTITIES OF WIRELESS ACCESS POINTS IS INDICATIVE, FINAL LOCATIONS AND QUANTITIES WILL BE AS PER APPROVED HEAT MAPS SUBMITTED BY CONTRACTOR AS PART OF SHOP
- 16. COORDINATE WIRELESS ACCESS POINT MOUNTING WITH ARCHITECTURE PACKAGE. 17. ALL ELECTROMECHANICAL SPACES AND STORES WITH WALL MOUNTED TELEPHONE OUTLET WILL BE
- PROVIDED WITH WALL MOUNTED TELEPHONE HANDSETS
- 18. PROVIDE ANALOG ADAPTORS FOR FAX MACHINES AT FACILITY MANAGEMENT AREA (WHERE 19. PROVIDE DIRECT TELEPHONE LINE TO FIRE ALARM PANEL FOR CIVIL DEFENSE COMMUNICATION.
- 20. PROVIDE TELEPHONE LINE WITH CONTROLLED ACCESS TO PUBLIC TELEPHONE SYSTEM AT FIRE COMMAND CENTER AS PER NFPA 72 REQUIREMENTS
- 21. FINAL DATA LINK CAPACITY WILL BE IN ACCORDANCE WITH SPECIFICATIONS AND APPROVED TRAFFIC CALCULATIONS SUBMITTED BY CONTRACTOR AS PART OF MATERIAL SUBMITTAL.
- 22. COORDINATE ROUTERS REQUIREMENTS WITH SERVICE PROVIDER
- 23. COORDINATE POWER REQUIREMENTS WITH ELECTRICAL PACKAGE. 24. AMPLIFIER RATING WILL BE AS PER SPEAKER TAPPING & QUANTITIES.
- 25. SPEAKER DISTRIBUTION AND TAPPING WILL BE ADJUSTED TO PROVIDE INTELLIGIBILITY &
- 26. PUBLIC ADDRESS SYSTEM WILL BE INTERFACED TO FIRE ALARM TO MUTE IN CASE OF FIRE.
- 27. THE CONTRACTOR WILL GUARANTEE THAT THE MINIMUM STI REQUIRED SHALL BE 0.5.
- 28. PUBLIC ADDRESS SYSTEM WILL UTILIZE THE SMART & SECURE NETWORK.
- 29. THE BUILDING CONTRACTOR SHALL COORDINATE WITH INFRASTRUCTURE CONTRACTOR FOR THE INFRASTRUCTURE TELECOM NETWORK (QPN & SSN) CABLES/DUCTS CONNECTED TO THE BUILDINGS.
- 30. FOR BUILDING CONNECTIVITY WITH TELECOM INFRASTRUCTURE NETWORKS (OPN, SSN), PLEASE REFER TO TELECOM INFRASTRUCTURE NETWORKS DRAWINGS NO. PE20851C-FD-SWO-TS-101, PE20851C-FD-SWO-TS-102, PE20851C-FD-SWO-TS-103, PE20851C-FD-SWO-TS-104, PE20851C-FD-SWO-TS-105, PE20851C-FD-SWO-TS-106, PE20851C-FD-SWO-TS-107, PE20851C-FD-SWO-TS-108, PE20851C-FD-SWO-TS-109,
- PE20851C-FD-SWO-TS-110, PE20851C-FD-SWO-TS-111, PE20851C-FD-SWO-TS-112, PE20851C-FD-SWO-TS-113, PE20851C-FD-SWO-TS-114, PE20851C-FD-SWO-TS-115, PE20851C-FD-SWO-TS-116, PE20851C-FD-SWO-TS-117, PE20851C-FD-SWO-TS-118, PE20851C-FD-SWO-TS-119, PE20851C-FD-SWO-TS-120.

SECURITY SYSTEMS NOTES

- 1. ALL CAMERAS (WITHIN THE BUILDING) SHALL BE CONNECTED TO THE NEAREST ONT. IF THE MAXIMUM DISTANCE BETWEEN ONT AND THE CAMERA EXCEEDS 90M, THEN FIBER OPTIC CABLES AND NECESSARY MEDIA CONVERTERS SHALL BE USED AND UPS POWER SHALL BE ARRANGE ACCORDINGLY. 2. CCTV CAMERAS LOCATIONS ARE INDICATED ON THE DRAWING APPROXIMATELY. EXACT LOCATIONS AND HEIGHTS SHALL BE DETERMINED WITH THE CONTRACTOR ON SITE DEPENDING ON THE BUILDING
- DECORATION, INTERIOR DESIGN AND ANY OTHER SERVICE APPLIANCE/COMPONENT. 3. VIDEO SURVEILLANCE SYSTEM SHALL BE IP BASED AND MINIMUM TWO MEGA-PIXEL RESOLUTION AS PER MOI REQUIREMENTS UNLESS OTHERWISE INDICATED.
- 4. VIDEO SURVEILLANCE STORAGE SHALL BE AS PER MOI REQUIREMENTS AND PROJECT SPECIFICATIONS.
- 5. WEATHER PROOF CAMERAS SHALL BE USED IN OUTDOOR AREAS.
- 6. THE SECURITY CONTRACTOR SHALL PROVIDE A SAMPLE OF EACH COMPONENT TO ARCHITECTS PRIOR TO RAISING INTERNAL STOCK ORDERS, FOR ARCHITECT APPROVAL. THE AESTHETICS OF ALL COMPONENTS ARE OF HIGH IMPORTANCE AND ALL FIXING METHODS, SIZES, COLOR, AND FINISH ARE TO BE COORDINATED AND AGREED WITH THE ARCHITECT PRIOR TO COMMENCEMENT OF WORKS.
- 7. THE DOOR DETAILS ARE MEANT TO BE DIAGRAMMATIC ONLY, SHOWING EQUIPMENT AND GENERAL WIRING INFORMATION. EXACT MOUNTING ACCESSORIES, MATERIAL TYPES, DOOR SWINGS, ETC. ARE NOT INDICATED AND ARE TO BE PROVIDED BY CONTRACTOR AS PART OF SHOP DRAWING.
- 8. THE CONTRACTOR WILL COORDINATE ALL ACCESS CONTROL SYSTEM EQUIPMENT WITH DOOR HARDWARE PACKAGE.
- 9.PROVIDE A DOOR INTERFACE BOX FOR EACH DOOR THAT IS LOCATED DIRECTLY ABOVE THE DOOR IN A CONCEALED, ACCESSIBLE AREA SUCH AS ABOVE THE CEILING FROM SECURED SIDE.
- 10. ALL CONDUITS WILL BE EMBEDDED OR ABOVE SUSPENDED CEILINGS 11. READER BACK BOXES WILL BE MOUNTED ON THE SIDE OF THE DOOR WHEREVER POSSIBLE WITH
- TOP OF THE BOX AT 1220mm A.F.F. 12. GUARD TOUR SYSTEM & TIME AND ATTENDANCE ARE INTEGRATED WITHIN THE SECURITY SYSTEM
- 13. THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROVIDING ALL PROGRAMMING FOR EACH DOOR FOR THE APPROPRIATE SEQUENCE OF OPERATION. THE SEQUENCE OF OPERATION SHALL INCLUDE, BUT NOT BE LIMITED TO, TIME SCHEDULES, ACCESS LEVELS, DESCRIPTIONS AND ALARM. THE PROGRAMMING SHALL INCLUDE CAMERA CALL-UP IF A CAMERA IS AVAILABLE TO VIEW THE DOOR
- UPON ALARM. 14. ALL OUTDOOR READER WILL BE WEATHER PROOF TYPE.

ABBREVIATIONS

PLATFORM.

- W.P. : WEATHER PROOF - FOV : FIELD OF VIEW



Project Name:

Governmental District The Presidential Park Egypt Administrative Capital

FOR CONSTRUCTION

Date App. Description Drawing Title:


TELECOM GENERAL NOTES


PRESIDENTIAL PARK


SYMBOLS AND ABBREVIATIONS


APPROVED PE20851C FD


Project No. | Phase | Project part | Department Acronym | Sheet No. |













ROLLING SHUTTER DOOR OPERATION:


CONTROL WORKSTATION.

- 1- THE ACCESS CONTROL SYSTEM SHALL CONTROL THE ROLLING SHUTTER DOORS BY INTERFACING WITH THE DOOR HARDWARE CONTROL PANEL AND THE DOOR OPEN/CLOSE SWITCH THAT SHALL BE SUPPLIED AND INSTALLED BY THE DOOR HARDWARE SUPPLIER.
- 2- A VALID CARD READER SHALL BE REQUIRED TO OPEN THE DOOR, AUTHORIZED ACCESS SHALL ENABLE THE OPEN/CLOSE BUTTON FOR A CERTAIN TIME TO ALLOW THE USER TO CONTROL THE DOOR.
- 3- THE ACCESS CONTROL SYSTEM SUPPLIER SHALL COORDINATE WITH THE MECHANICAL DOOR CONTROL PANEL SUPPLIER TO GET SIGNALS FOR THE DOOR STATUS. I.E. DOOR HELD OPEN, DOOR FORCED OPEN AND REX SIGNAL.
- 4- THE ACCESS CONTROL SYSTEM SHALL ALLOW DOOR OPENING FOR CERTAIN TIME DEFINED BY USER, IF THE DOOR HELD OPEN FOR TIME EXCEEDING THE DEFINED TIME, A SIGNAL SHALL BE SENT TO ACTIVATE AN AUDIO- VISUAL ALARM THAT SHALL BE INSTALLED NEAR TO THE DOOR. A VALID CARD READER SHALL
- DEACTIVATE THE ALARM.

 5- IF THE DOOR IS FORCED OPEN WITHOUT A VALID CARD READER OR REX SIGNAL, THE AUDIO VISUAL ALARM SHALL BE ACTIVATED, AND A DOOR FORCED OPEN ALARM SHALL BE ACTIVATED AT THE SECURITY
- 6- SHUTTER DOOR SHALL BE INTERFACED WITH FIRE ALARM SYSTEM SUCH THAT IN CASE OF FIRE THE DOOR CONTROL BUTTON SHALL BE ACTIVATED WITHOUT PREVIOUS AUTHENTICATION AND A SIGNAL SHALL BE SENT TO THE SECURITY ROOM ACS MONITORING WORKSTATION.







NON-PUBLIC

CIRCULATION

REX

CIRCULATION

EXTERIOR

EXTERIOR

CIRCULATION

NON-PUBLIC CIRCULATION

SERVER ROOM

ROOMS/ CLOSETS

ELECTROMECHANICAL

ROOMS

CONTROL ROOM

SERVICE PROVIDER

ROOMS/ CLOSETS

FIRE COMMAND

CENTER

ELECTROMECHANICAL

CLOSETS


MOVEMENT TO


SERVER ROOM

TELECOM

ROOM/ CLOSETS

ELECTROMECHANICAL





CONTROL ROOM	SERVICE PROVIDER ROOMS/ CLOSETS	FIRE COMMAND CENTER	ELECTROMECHANICAL CLOSETS	
CR	CR	CR*1	DC	
CR	CR	CR*1	DC	
			/////////	

AREA NAME	AREA DESCRIPTION
EXTERIOR	AREA OUTSIDE THE BUILDING
PUBLIC CIRCULATION	PUBLIC AREAS (LOUNGES. LOBBIES, PUBLIC CORRIDORS , ETC)
NON-PUBLIC CIRCULATION	NON PUBLIC AREAS (STAFF CIRCULATION)
SERVER ROOM	ROOM HOUSING THE SERVICE RACKS AT OPERATION CENTER
TELECOM ROOMS/ CLOSETS	ROOMS HOUSING THE TELECOM RACKS AT EACH BUILDING
ELECTROMECHANICAL ROOMS	LARGE UTILITY ROOMS (MV, GENERATOR, UPS, TRANSFORMER, LARGE MECHANICAL ROOMS, ETC)
CONTROL ROOM	CONTROL ROOM HOUSING WORKSTATIONS AT OPERATION CENTER
SERVICE PROVIDER ROOM/ CLOSETS	ROOMS HOUSING SERVICE PROVIDER EQUIPMENTS
FIRE COMMAND CENTER	ROOM HOUSING FIRE PANELS AND WORKSTATIONS
ELECTROMECHANICAL CLOSETS	CLOSETS HOUSING ELECTRICAL AND MECHANICAL EQUIPMENT

	ACCESS CONTROL KEY				
CR	CARD READER WITH INTEGRATED BUZZER				
DC	DOOR CONTACT				
REX	REQUEST TO EXIT				
	FREE MOVEMENT				
CR*1	CARD READER AND BREAK GLASS UNIT AT LOWER SECURITY SIDE				
	NOT APPLICABLE				

ACCESS CONTROL SYSTEM CABLING:

THE CABLES LISTED BELOW ARE THE GENERIC CABLE TYPES USED TO SIZE THE CONDUITS IN THE FOLLOWING DETAILS .CONTRACTOR SHALL VERIFY THE MANUFACTURER'S RECOMMENDED CABLES FOR HIS SYSTEM AND USE THE APPROPRIATE CABLE TYPES .ANY INCREASE IN CONDUIT SIZE DUE TO THE SYSTEM CHOSEN SHALL BE THE CONTRACTOR'S RESPONSIBILITY . THE FOLLOWING CABLE TYPES ARE GIVEN FOR REFERENCE PURPOSES ONLY. ALL CABLES PROVIDED AS PART OF THIS CONTRACT SHALL BE RATED FOR THE ACTUAL INSTALLATION .THE SIZES OF SOME OF THESE CABLES MAY VARY ,AND THE CONDUIT SIZE SHALL BE ADJUSTED ACCORDINGLY .IF ANY CABLES NOT APPROPRIATELY RATED FOR THE USE ARE DISCOVERED DURING THE COURSE OF THIS PROJECT THAT WERE PROVIDED BY THIS CONTRACTOR ,THE CONTRACTOR WILL BE HELD RESPONSIBLE FOR REPLACING THOSE CABLES AT NO COST TO THE EMPLOYER. DESCRIPTION CABLE TYPE CARD READER CABLE 4 PAIR 18 AWG SH DOOR CONTACT CABLE 2 CONDUCTOR 22 AWG UN-SH REQUEST TO EXIT/MONITORING 4 CONDUCTOR 22 AWG UN-SH LOCK CABLE/POWER CABLE 2 CONDUCTOR 16 AWG UN-SH

2 CONDUCTOR 22 AWG UN-SH

7 CONDUCTOR 16AWG UN-SH

BREAK GLASS UNIT CABLE

OUTPUT CABLE

	•	SYSTEM	DETAIL	S		
DESIGNED		CHECKED		APPROVED		
W.A.		N.S.		M.K.		
DRAWN		DATE		SCALE		
A.S.		28/01/2021		NTS		

Project No. Phase code Project part Department Acronym Sheet No.

PRESIDENTIAL PARK

IP ACCESS CONTROL

FOR CONSTRUCTION

GENERAL REVISION

APPROVED ISSUE

Description

Drawing Title:

09/03/2021


28/01/2021

Date App

اله

يئة الهندسية للقوات المسلحة

Client:



Project Name:

Governmental District

The Presidential Park
Egypt Administrative Capital

NOTES:

1. FOR GRAPHICAL SYMBOLS, ABBREVIATIONS AND GENERAL NOTES REFER TO DRAWING NO. PE20851-FD-GEN-TG-001.

2. THE DOOR DETAILS ARE MEANT TO BE DIAGRAMMATIC ONLY, SHOWING EQUIPMENT AND GENERAL WIRING INFORMATION. EXACT MOUNTING ACCESSORIES, MATERIAL TYPES, DOOR SWINGS, ETC. ARE NOT INDICATE AND ARE TO BE PROVIDED BY CONTRACTOR AS PART OF SHOP DRAWING.

3. THE CONTRACTOR WILL COORDINATE ALL ACCESS CONTROL SYSTEM EQUIPMENT WITH DOOR HARDWARE PACKAGE.

4. THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROVIDING ALL PROGRAMMING FOR EACH DOOR FOR THE APPROPRIATE SEQUENCE OF OPERATION. THE SEQUENCE OF OPERATION SHALL INCLUDE, BUT NOT BE LIMITED TO, TIME SCHEDULES, ACCESS LEVELS, DESCRIPTIONS AND

ALARM. THE PROGRAMMING SHALL INCLUDE CAMERA CALL-UP IF A CAMER

IS AVAILABLE TO VIEW THE DOOR UPON ALARM.